

Meeting	CABINET
Time/Day/Date	5.00pm on Tuesday, 11 December 2018
Location	Board Room, Council Offices, Coalville
Officer to contact	Democratic Services (01530 454512)

NOTICE UNDER THE LOCAL AUTHORITIES (EXECUTIVE ARRANGEMENTS) (MEETINGS AND ACCESS TO INFORMATION) (ENGLAND) REGULATIONS 2012

The Chairman of the Policy Development Group has been consulted and has agreed that the following additional item is to be considered as a Key Decision under the special urgency provisions of the Local Authorities (Executive Arrangements) (Meetings and Access to Information) (England) Regulations 2012.

PROVISION OF FUNDING TO UPGRADE FIRE ALARM AND DOOR ENTRY SYSTEM TO THE COUNCIL OFFICE BUILDING

Report of the
Presented by the

The reason why compliance with Regulation 9 of the Local Authorities (Executive Arrangements) (Meetings and Access to Information) (England) Regulations 2012 was impracticable is as follows:

To approve an amendment to the 2018/19 approved budget for the prompt replacement of the door entry and fire alarm systems to the Council Office building.

Following a power cut to the building on 27 November 2018 issues were identified with the door entry system which required us to reassess the proposed timetable for installation of the systems, and bring the date forward to be as soon as possible. The issue related to the default “locked” position of the doors, which could prevent effective checking of the building during an evacuation in the event of another power failure.